INDOOR WIRING DIAGRAM



OPTIONAL

S1_1	S1_2	TYPE
OFF	OFF	9K
ON	OFF	12K
OFF	ON	18K
ON	ON	24K

S2	FUNCTION
ON	COOL ONLY
OFF	COOL/HEAT

After-sale service

- - - - This symbol indicates the element is optional,the actual shape shall prevail.

FOR SETTING NETADDRESS (CCM Comm.Bus)

ENC3+F1 (MULTI-FUNCTION CONTROL BOARD)							
CODE	0~F		0~F		0~F		0~F	
NETADDRESS	0~15		16~31		32~47		48~63	
FACTORY SETTING	✓							